## G.EDGAR HARR SONS' CORPORATION 12047 FALLS ROAD COCKEYSVILLE MD 21030 410-252-4588 410-560-0784 FAX

## Drilling Contract

William Shinholt 6014 Burnt Oak Road Catonsville, MD 21228 April 18, 2000

788-8915

- 1. Drill 6" well for \$8.50 per foot
- 2. Furnish 20' of 6" casing, extra casing 4.75 per foot (PVC) or 6.50 per foot (Steel) \*Circle Preffered material.
- 3. Cement grouting of well casing \$275.00 per well.
- 4. Well yield test \$255.00 per well.
- 5. Abandoned or Dry holes at a rate of \$ 4.50 per foot
- 6. All drilling debris to be left on site.
- 7. Must have access to the drilling site. Customer agrees to furnish a tractor to gain access to or exit from the job site, if needed.
- 8. Not responsible for trees, lawns, and driveways damaged by the movement of equipment.
- 9. Permit and well cap \$60.00 per well.
- 10. Mobilization \$00.00

Vice President

- 11.A DEPOSIT OF \$1500.00 IS REQUIRED, REMAINING BALANCE DUE UPON COMPLETION OF THE WORK. INVOICES NOT PAID WITHIN 15 DAYS ARE SUBJECT TO INTEREST OF 1 1/2% PER MONTH ON OUTSTANDING BALANCE. A 30% LEGAL FEE WILL BE PAYABLE ON OUTSTANDING BALANCES SHOULD THE ACCOUNT BE PLACED FOR COLLECTION
- 12. Completion and yield reports will be submitted to the customer upon final payment. These reports are required for building permits and settlement.
- 13. Location of job site Dogwood Road

In this contract the term WELL shall consist of the hole caused by drilling and casing only. It is agreed that the above amounts are payable whether water is obtained or not. Our only obligation being to perform the drilling operation. The driller reserves the right to reduce the size of the well and casing and/or abandon drilling. Well site is subject to approval of the local Health Department.

Contract Accepted:	Date 7/28/00	^
G. Edgar Harr Sons' Corp.	Signed William	Shenhalt
Michael Isom	Signed	-

## FIELD DATA SHEET BALTIMORE COUNTY WELL YIELD TEST REPORT

APPROVED BY WATER & SEWER DIVISION, ENVIRONMENTAL PROTECTION & RESOURCE MANAGEMENT Valid Until

Address Wrights Mill Road	Well Driller/Tester G. Edg	Signature & Date car Harr Sons' Corp Elec. District	
Subdivision	Lot Block .	Plat Section	
Owner & Mailing Address William Depth of Well 275 Ft.	Shinholt,, 6014 Burnt Oak	Road, Catonsville,, MD 21228	
Commence of the Commence of th	Static Wat	er level 46'	ì

Pump Test Data - Observations to be Recorded Every

TIME	WATER	PSI (existing pump)	H RATE PUMPING RESERV  PUMPING RATE  time to fill >gal.  bucket	ADDITIONAL DATA	CALCULATED FLOW (gal. per minute)
9830	46'		20		15.00
0845	99'		20		1500
0900	131'		32		13.63
0915	144'		22		13.63
0930	153'		25		12-00
0945	160'		25		
1000	169'		25		12.00
1015	174"	and the second s	25	•	12.00
1030	183'		25		12-00
1045	183'	0	25	/	12.00
1100	183'		25		12.00
1115	/83'	>	25		12.00
1130	183'		25		12.00
•					12.00
.41		• •	.,		-1
	13.4				
	.,				
1	17				•
		13			
111					