

# FOUNTAIN VALLEY ANALYTICAL LABORATORY, INC.

1413 Old Taneytown Rd. Westminster, MD (410) 848-1014 (410) 876-4554

## REPORT OF ANALYSIS

|                       |  |               |                               |
|-----------------------|--|---------------|-------------------------------|
| Laboratory ID #:      | 159809                                       | Account #:    | 1933                          |
| Reference:            | Barb Bindon                                  | Client:       | Fogle's Well Pump & Treatment |
| Location:             | 26115 Frederick Road<br>Clarksburg, MD 20871 | Requested By: | Dave Fogle                    |
| Date/ Time Collected: | 6/26/2023 0815                               | Source:       | Well Water                    |
| Date/Time Rec'd:      | 6/26/2023 1008                               | Site:         | Hose Bib                      |
| Chlorine ppm:         | Free: ND Total: ND                           | Treatment:    | UV Light/Sediment Filter      |
| Collected By:         | J. Evans 0309JE                              | pH:           | 6.2                           |
|                       |  | Well #:       | N/A                           |

| PARAMETERS | RESULTS | UNITS | REFERENCE | METHOD   | DATE/TIME/ANALYST      |
|------------|---------|-------|-----------|----------|------------------------|
| Lead       | 0.010   | mg/L  | 0.015     | SM3113-B | 7/10/2023 / 1522 / KMW |

### NOTES:

- 1 Lead collected as a 1st draw sample
- 2 Lead Detection Limit: 0.005 mg/L
- 3 mg/L = milligrams per liter (also, parts per million)
- 4 Results less than or within the reference range are considered satisfactory and within potable water limits at the time of sampling.
- 5 Sub-contracted to Reference Lab #116
- 6 ND = None Detected; N/A: Not Available
- 7 pH and Chlorine level tested in lab (pH tested after recommended holding time)
- 8 Visual well check: Single piece cap

**Reason for Test :** Client's Information

Date Reported: 7/11/2023